

Gobers LLC
11215 E Trent Ave
Spokane Valley, WA 99206

Sewer, Septic, & Pump Solutions

Phone: 509-924-5372
Fax: 509-926-8373
atrustedname@aol.com

Invoice
20867

Date: 8/6/24

To:

Customer Name Carnahan Crest Homeowners Assn

Address 1808-1810 S Viewcrest Ln, 99212,

Spokane Valley, WA 99212

Phone 206-434-9155 (Gary Teale)

DESCRIPTION	QTY	PRICE	AMOUNT
Pump 1500 Gal			869.00
Dig			250.00
Multi-Tank Discount			-25.00
			1,094.00
CHL6			
Paid by _____	TAX		97.37
Received by _____	TOTAL		1,191.37

Credit Card Fee 2.5%

Technician Notes/Recommendations:

- Lids Secured
- Outlet lid under concrete for stairs
- Inlet line is settled slightly
- Quote for risers 1x9in, 1x16in risers
- w/out lid removal \$480.79
- w/ lid removal \$535.24

Technician's Name: JK/FH

ROL yes no
Home occupied vacant

Persons in Home _____

Years Last Pumped _____

Pump Chamber:

Pumped yes no

Needs Svc? yes no

Water Softener yes no

Inlet Line ok belly settled

Outlet Line ok settled

Tank septic cesspool

Lids

Qty 1 2 3
Condition good fair poor

Depth of Lids 9in 16in

Risers Recomm. yes no

Liquid Levels normal high low

Scum Blanket Depth 1in

Sludge Blanket Depth 16in

Effluent Run Back yes no

Inlet Baffle good fair poor

Outlet Baffle good fair poor

Flow from House good no one home

Effluent Filter good needs service

Recommendations

Roebic Drain yes no

Roebic Root yes no

Trap Cleaner yes no

Purge yes no

Customer States:

Septic Systems are underground making it impossible to state, with certainty, their overall condition. All systems require regular maintenance such as pumping. NO ONE can predict when a system will fail. This report comments only the functionality on the day of the inspection and is not a warranty.

Make all checks payable to: Gobers LLC

Total due in 10 days. Overdue accounts subject to a service charge of 1% per month.

"a trusted name since 1951"

BK