

Gobers LLC

Sewer, Septic, & Pump Solutions

11215 E Trent Ave
Spokane Valley, WA 99206

Phone: 509-924-5372
Fax: 509-926-8373
atrustedname@aol.com

Invoice
20866

Date: 8/6/24

To:

Customer Name Cannabary Crest Homeowners Assn

Address 1802-1804 S Viewcrest Ln, Spokane

Valley, WA 99212

Phone 206-434-9155 (Gary Teale)

DESCRIPTION	QTY	PRICE	AMOUNT
Pump 1500 Gal			869.00
Pig			250.00
Multitank - Tank Decant			-25.00
			1,094.00
(CHL6)			
Paid by _____	TAX		97.37
Received by _____	TOTAL		1,191.37

Technician Notes/Recommendations:

Lids Secured
Can't see Inlet Baffle or line
Quote for risers 1x10" riser 1x9" riser
w/out lid removal \$438.32
w/lid removal \$492.77

Technician's Name: JK/FH

Septic Systems are underground making it impossible to state, with certainty, their overall condition. All systems require regular maintenance such as pumping. NO ONE can predict when a system will fail. This report comments only the functionality on the day of the inspection and is not a warranty.

Make all checks payable to: Gobers LLC

Total due in 10 days. Overdue accounts subject to a service charge of 1% per month.

ROL yes no
Home occupied vacant
Persons in Home _____
Years Last Pumped _____
Pump Chamber:
Pumped yes no
Needs Svc? yes no
Water Softener yes no
Inlet Line ok belly
Outlet Line ok settled
Tank septic cesspool
Lids
Qty 1 2 3
Condition good fair poor
Depth of Lids 10m/9m
Risers Recomm. yes no
Liquid Levels normal high low
Scum Blanket Depth 3m
Sludge Blanket Depth 10in
Effluent Run Back yes no
Inlet Baffle good fair poor
Outlet Baffle good fair poor
Flow from House good no one home
Effluent Filter good needs service
Recommendations

Roebic Drain yes no
Roebic Root yes no
Trap Cleaner yes no
Purge yes no

Customer States:

Sprinkler lines over lids

"a trusted name since 1951"