

Gobers LLC

Sewer, Septic, & Pump Solutions

11215 E Trent Ave
Spokane Valley, WA 99206

Phone: 509-924-5372
Fax: 509-926-8373
atrustedname@aol.com

Invoice
20870

Date: 8/17/24

To:

Customer Name: Carnahan Crest Homeowners Assn
Address: 1822-1820 S Viewcrest Ln, Spokane Valley, WA 99012
Phone: 206-434-9155 (Gary Teale)

DESCRIPTION	QTY	PRICE	AMOUNT
Pump 1500 Gal			869.00
Dis Multi-Tank Discount			25.00
			1,094.00
CH6			

Paid by _____ TAX 97.37
Received by _____ TOTAL 1,191.37

Technician Notes/Recommendations:

Lids Secured
Quote for risers x2 1x12in 1x10in
w/out lid removal \$459.56
w/lid removal \$514.01

Technician's Name: JK

ROL yes no
Home occupied vacant
Persons in Home _____
Years Last Pumped _____
Pump Chamber:
Pumped yes no
Needs Svc? yes no
Water Softener yes no
Inlet Line ok belly
Outlet Line ok settled
Tank septic cesspool
Lids
Qty 1 2 3
Condition good fair poor
Depth of Lids 12 10 in
Risers Recomm. yes no
Liquid Levels normal high low
Scum Blanket Depth 6 in
Sludge Blanket Depth 8 in
Effluent Run Back yes no
Inlet Baffle good fair poor
Outlet Baffle good fair poor
Flow from House good no one home
Effluent Filter good needs service
Recommendations
Roebic Drain yes no
Roebic Root yes no
Trap Cleaner yes no
Purge yes no

Customer States:

Septic Systems are underground making it impossible to state, with certainty, their overall condition. All systems require regular maintenance such as pumping. NO ONE can predict when a system will fail. This report comments only the functionality on the day of the inspection and is not a warranty.

Make all checks payable to: Gobers LLC

Total due in 10 days. Overdue accounts subject to a service charge of 1% per month.

"a trusted name since 1951"

BA