

Gobers LLC

Sewer, Septic, & Pump Solutions

11215 E Trent Ave
Spokane Valley, WA 99206

Phone: 509-924-5372
Fax: 509-926-8373
atrustedname@aol.com

Invoice
20954

Date: 8/9/24

To:

Customer Name Carnahan Crest Homeowners Assn
Address 1814-1816 S Viewcrest Ln, Spokane
Valley, WA 99212
Phone 206-234-9155 (bary Teale)

DESCRIPTION	QTY	PRICE	AMOUNT
Pump 1500 Gal	2		869.00
Dog			415.00
New lid			50.00
Multi-tank Decant			-25.00
			<u>1,309.00</u>
CH6			
Paid by _____		TAX	116.50
Received by _____		TOTAL	1,425.50

Technician Notes/Recommendations:

Lids Secured
Quote for river for Outlet Side 14 1/2 in
w/lid removal \$338.68
w/out lid removal \$311.45

Technician's Name: JK/RI

Septic Systems are underground making it impossible to state, with certainty, their overall condition. All systems require regular maintenance such as pumping. NO ONE can predict when a system will fail. This report comments only the functionality on the day of the inspection and is not a warranty.

Make all checks payable to: Gobers LLC

Total due in 10 days. Overdue accounts subject to a service charge of 1% per month.

ROL yes no
Home occupied vacant
Persons in Home _____
Years Last Pumped _____
Pump Chamber:
Pumped yes no
Needs Svc? yes no
Water Softener yes no
Inlet Line ok belly
Outlet Line ok settled
Tank septic cesspool
Lids
Qty 1 2 3
Condition good fair poor
Depth of Lids 14in/28in
Risers Recomm. yes no
Liquid Levels normal high low
Scum Blanket Depth 10in
Sludge Blanket Depth 6in
Effluent Run Back yes no
Inlet Baffle good fair poor
Outlet Baffle good fair poor
Flow from House good no one home
Effluent Filter good needs service
Recommendations
Roebic Drain yes no
Roebic Root yes no
Trap Cleaner yes no
Purge yes no

Customer States:

"a trusted name since 1951"