

Gobers LLC

Sewer, Septic, & Pump Solutions

11215 E Trent Ave
Spokane Valley, WA 99206

Phone: 509-924-5372
Fax: 509-926-8373
atrustedname@aol.com

Invoice

20953

Date: 8-8-24

To:

Customer Name Carrahan Crest Homeowners
Address 1819-1821 S Viewcrest Ln.
Spokane Valley WA, 99212
Phone 206-434-9155

DESCRIPTION	QTY	PRICE	AMOUNT
- pump 1500 gallon septic tank			\$869.00
- \$25 discount off			\$-25.00
- Dig			\$250.00
			<u>2094.00</u>
			97.37
Paid by <u>CHG</u>		TAX	\$75.00
Received by _____		TOTAL	\$919.00

Technician Notes/Recommendations:

- lid secure

Quote for risers - 2 - lids
24" material @ \$6.50/in = \$156
2 - lids @ \$92/lid = \$194
SVC fee = \$85
\$435 tax
\$38.72
\$473.72 total

Technician's Name: Flj

Old Lid Removal - \$25/Lid = \$150 + \$435 = \$485
tax = 43.17 total = \$528.17

Septic Systems are underground making it impossible to state, with certainty, their overall condition. All systems require regular maintenance such as pumping. NO ONE can predict when a system will fail. This report comments only the functionality on the day of the inspection and is not a warranty.

Make all checks payable to: Gobers LLC

Total due in 10 days. Overdue accounts subject to a service charge of 1% per month.

ROL yes no
Home occupied vacant
Persons in Home _____
Years Last Pumped _____
Pump Chamber:
Pumped yes no
Needs Svc? yes no
Water Softener yes no
Inlet Line ok belly
Outlet Line ok settled
Tank septic cesspool
Lids
Qty 1 2 3
Condition good fair poor
Depth of Lids 1 ft
Risers Recomm. yes no
Liquid Levels normal high low
Scum Blanket Depth 7 inches
Sludge Blanket Depth 5 inches
Effluent Run Back yes no
Inlet Baffle good fair poor
Outlet Baffle good fair poor
Flow from House good no one home
Effluent Filter good needs service

Recommendations

Roebic Drain yes no
Roebic Root yes no
Trap Cleaner yes no
Purge yes no

Customer States:

With Lid Removal

"a trusted name since 1951"

8/10